

## Fannin County Initial Inspection by Master Electrician Findings

### Fire Pump Controller

1. Fire pump and controller must be installed in a 2-hour fire rated room. This is a Uniform Building Code requirement. **Not Electrical Scope.**
2. Service feeder needs to be incased in concrete. Service conductors must be routed outside of the building. NEC 230.3 **N/A. This building is a single serviced building. It is not required to be concrete encased.**
3. Utility Company Transformer supplied service, not grounded, not bonded. No grounded service conductor installed; no effective ground fault current path. 250.24D Neutral conductor needs to be extended to the Fire Pump Controller per typical service bonding requirements. **A ground is not required from the xfrm to the fire pump. Neutral conductor will be extended to fire pump controller.**
4. Generator feeder conductors need to be incased in concrete or fire resistant conductors. **Not required by code.**
5. Conduits impeding clearance requirements, NEC 110 **Conduits changed and waiting on platform.**
6. Feeders not complete runs, NEC 300-18 **Per NEC 300.18 Raceway was completely installed before wire was installed.**
7. Sources not labeled. **Complete**
8. Bushing missing on motor feeder. **Added bushing.**
9. Motor feeder ground, not identified by proper color if # 4 or smaller. **N/A per NEC 2014**
10. Service conductors are too short and cannot be properly managed. **This will be repaired when #5 is addressed.**
11. Feeder conduits not supported. **This will be repaired when #5 is addressed**
12. Feeder conduits are obstructing access to valve. **This will be repaired when #5 is addressed**
13. Fire Pump Controller short circuit protection may be incorrect. NEC 695 requires the short circuit rating be based on the locked rotor amp rating of the motor plus 100 percent of the total associated loads. Motor data indicates LRA to be 498 amps, total other load, 88 amps = 586A, per NEC 240.6 OCPD size 600A. Additionally, the fire pump control panel drawings indicate short circuit protection trip setting is 1050A. Current generator fire pump feeder circuit is 400A. It is worth noting that the feeder wire size is much larger than what is required by the code. Fire pumps fall under an exception that requires the motor load wiring to be 125% of the rating. In this case  $88A \times 125\% = 110A$  CU wire rated for 115A @75 degrees. Current installation utilized 4/0 AL wire, rated for 180A. **Fire pump controller was supplied by others. Current wiring is correct per code for the motor load.**
14. Comments regarding Fire Pumps. Fire pumps are typically accessed by Fire Fighters to control the flow of water for two main reasons. First, controlling water pressure to the fire sprinklers for firefighting purposes. Second, to manage flood control. Without access to the equipment there would be no way for the Fire Fighters to shut off the fire pump and prevent the basement from flooding. The current arrangement, is arguably considered a confined space especially if one considers the building is on fire. Typical structures that justify a fire control room or pump room would have an external access to the room. Remember, there is no way to shut off power to the pump

controller unless the power company de-energizes the transformer that supplies power to the building. **Installed per engineered drawings.**

15. Variances: variances for historical buildings are usually accompanied by a paper trail of officials that have signed off on the modification of the code.

16. The 2-hour fire rating applies to the room that the equipment is installed and the corridor that leads to that room.

### Fire Pump Feeders

1. Junction boxes are too small. Code requires 18 inches of separation between the conduits inside the junction box. **Code requires 18 inches of separation on pull boxes but not junction boxes.**
2. The feeder from the utility company transformer should be installed per electrical service requirements. Bonding bushings are missing. **Per code bonding bushings are only required for concentric knockouts.**
3. Enclosures are not bonded. **Complete**
4. Conduits are not sealed. **Complete**
5. Plastic bushing missing on customer side feeder. **Complete**
6. Mechanical execution of work not to standard.
7. Boxes are not labeled. **Complete**
8. Feeder conductors are not protected from potential damage by fire, structural failure or operational accident NEC 695.6 **Will be addressed with #5 of Fire Pump controller.**

### Generator Feeder to ATS

1. Junction box is too small.
2. Distance between conduits inside box should be at least 12.”
3. Box not supported. NEC 314.23 **Repaired**
4. Box is damaged. **Replaced**
5. No plastic bushings protecting conductors. **Plastic bushing installed**
6. Box is not bonded. **Complete**
7. Feeder conduit is not supported. **Complete**
8. Conduit penetration is not sealed. **Complete**
9. Conduits (inside) are not sealed. **Complete**
10. Box not labeled. **Complete**

### Panel DP - Basement

Answer #3. Labeled at main service per article 110.24.

1. Incoming feeder conduits are leaking water. Underground raceway seal 300.5G not provided. Water ingress through conduits is flooding the basement and corroding the electrical panel and support structure.
2. Incoming feeder conductors may not have the required minimum bending space, Table 312.6(A) (B) - Minimum wire bending space - Cabinets, cutouts and socket enclosures, wires size 500MCM required 6-14 inches per condition. This panel was not designed to accept these larger conductors entering on the side at this elevation of the panel.
3. Available short circuit rating may be required and labeled as such on the panel.
4. Calculated load for this panel, per the engineered drawings was 909 A (amps). Feeder overcurrent protective device (OCPD) is set for 1000A. Feeder wires are not sized in accordance with the code. The current installation is rated to serve 840A. Installer utilized aluminum conductors in parallel x 3 runs, 500MCM AL, 75-degree rating would yield 930A, however they failed to account for derating the wire size for having a neutral (grounding electrode conductor) which increases the conductor count from 3 to 4 in which case the code requires that the wire be derated to 80% of current carrying capacity. **It is a balanced 3 phase load and the neutral is not a current carrying conductor.**
5. Required clearance in front of panel is obstructed by conduit support.
6. Ground conductor to ground rod is aluminum, not permitted in the bottom 18 inches of any enclosure. **Complete.**
7. Code requires the disconnect to be lockable. There should be lock out devices on the sub feeder circuit breakers. Section 110.25 NEC **Locks have been ordered and waiting on delivery date.**

1. Domestic water not bonded. All metal water pipe should be at bonded and when applicable made a part of the building grounding electrode system.
  - 2.
  - 3.
- 250.68 Grounding Electrode Conductor and Bonding Jumper Connection to Grounding Electrodes.

The connection of a grounding electrode conductor at the service, at each building or structure where supplied by a feeder(s) or branch circuit(s), or at a separately derived system and associated bonding jumper(s) shall be made as specified 250.68(A) through (C).

(A) Accessibility.

All mechanical elements used to terminate a grounding electrode conductor or bonding jumper to a grounding electrode shall be accessible.

Exception No. 1:

An encased or buried connection to a concrete-encased, driven, or buried grounding electrode shall not be required to be accessible.

Exception No. 2:

Exothermic or irreversible compression connections used at terminations, together with the mechanical means used to attach such terminations to fireproofed structural metal whether or not the mechanical means is reversible, shall not be required to be accessible.

#### (C) Grounding Electrode Conductor Connections.

Grounding electrode conductors and bonding jumpers shall be permitted to be connected at the following locations and used to extend the connection to an electrode(s):

- (1) Interior metal water piping that is electrically continuous with a metal underground water pipe electrode and is located not more than 1.52 m (5 ft) from the point of entrance to the building, as measured along the water piping, shall be permitted to extend the connection to an electrode(s). Interior metal water piping located more than 1.52 m (5 ft) from the point of entrance to the building, as measured along the water piping, shall not be used as a conductor to interconnect electrodes of the grounding electrode system. Exception: In industrial, commercial, and institutional buildings or structures, if conditions of maintenance and supervision ensure that only qualified persons service the installation, interior metal water piping located more than 1.52 m (5 ft) from the point of entrance to the building, as measured along the water piping, shall be permitted as a bonding conductor to interconnect electrodes that are part of the grounding electrode system, or as a grounding electrode conductor, if the entire length, other than short sections passing perpendicularly through walls, floors, or ceilings, of the interior metal water pipe that is being used for the conductor is exposed.

Generator



1. Generator mounted too close to main electrical service, violating clearance requirements. Close proximity to Electrical Service enclosure could impede the require air flow to the generator. **Cummins confirmed the load bank was done and there are no issues with air flow.**
2. Generator is not bolted to the concrete pad. **Complete**
3. Generator circuit breakers are not labeled. **Complete**
4. Generator hot start does not appear to be working. **Complete. Changed out the block heater.**
5. Generator ground, connection buried in earth and or inside concrete pad. May or may not be listed for application. **Complete**
6. Concrete pad is stacked, potentially structurally un sound. **This was done by concrete sub.**
7. Fire pump circuit breaker may be undersized. **Installed per engineered drawings.**
8. Surface of working space needs to be level and flat.
9. Generator annunciator panel is installed on the transfer switch inside the basement. Typical installation locations for this panel are; (1) in a fire control room, (2) adjacent to the Fire Alarm Control Panel (FACP) (3) near the entrance of the Fire fighters Knox box ( a locked box that contains the key to the building accessible by fire fighters.  
**Fire Marshal is ok with the location of the annunciator.**

## Main Service

1. Ground electrode conductor connection to ground rod completed with aluminum wire and buried in earth. **Ground changed to copper**
2. Panel DP Feeder conductors are undersized. Refer to Panel DP item for calculation and photos.
3. Labeling required. **Complete**
4. Code requires the disconnect to be lockable. There should be lock out devices on the sub feeder circuit breakers. Section 110.25 NEC **The Nema3R enclosure is lockable.**
5. Surge protection is off. **Surge protection is working**
6. Surface of working space needs to be level and flat.

## Attic Wiring

1. Improper size junction boxes. **1 and 2 will be repaired when we schedule the**
2. Feeder conduits too close together for angle pulls. **shutdown.**
3. Branch circuits are not properly derated for the number of conductors in the conduit. **Complete**
4. Branch circuits are not properly derated for ambient temperature conditions. **Complete**

5. Too many conductors in box.  $28 \times 2 = 56$  current configuration based on Table 314.16(A) alone would limit the #10 conductors to 32. Box Would have to be at least  $12 \times 12 \times 4$ . Complete
6. Too large of a conduit in a box. Complete
7. Using conduit to support another conduit. Complete
8. Multiple supporting violations. Complete
9. Clearance issues for air handler safety switches. The stairs will need to be moved.
10. No bonding Complete
11. Conductor calculation: (28) #10 THHN CU, ambient temperature of 122 degrees F, 20A circuit breakers and 1-1/4" EMT.  $2.4 \text{ Cu/In per \#10 conductor} \times 40\text{A @90D C} \times .45 = 18\text{A}$ . Ambient temperature adjustment,  $114\text{-}122 \text{ Deg F} \times .82 \times 18\text{A} = 14.76\text{A}$ . Maximum circuit breaker allowed is 15A. Complete

## Basement Panel

1. Clearance violation on panel Complete

### Additional Items repaired

1. Bottom of Panel DP has been cleaned.
2. Rusted strut stand has been replaced.
3. Added a light above fire pump controller.
4. Sump pump control box was taken off the stand in the room and mounted on a strut rack from the ceiling.
5. 4 square j-box in the basement was too small. This was replaced with a 6"x6" j-box to meet code.
6. Unit heater conduits were supported correctly in the attic.
7. We are currently changing out the boxes for the lights on the second level and supporting them correctly. We are also putting the receptacle added for the Christmas wreaths on the new j-boxes.
8. The flagpole lights are not turning off during the day. Photocell was bad and we have replaced it.
9. We put the all restroom lighting on an emergency circuit.
10. Replaced sensors and added sensors where needed.









## Pow-R-Line® Xpert

PRL4

Panelboard

Pnl. Type	PRL4B	Pnl. Amps	1200
Volts	208Y/120V	Phase	3 Wire 4
Neut. Cat	6572C66G04	Neut. Amps	1200
Date	11/3/2020	Neut. Volts	120
Box Cat	BX3673P	Box Type	1
Job No.	SDA1136067-009	Mfdg. At	GPS

\*Maximum - See Main Circuit Breaker Rating.

Suitable for use as service equipment when:

- a) Not more than six disconnecting means are provided, and
- b) When not used as a lighting and appliance branch-circuit panelboard, and
- c) When main bonding jumper Type PRLMBJ is installed in the panelboard if the panelboard is equipped with an insulated grounded circuit conductor (neutral), and
- d) When service barrier Type PRLSEB is installed on a circuit breaker being used as a single service disconnect within the panelboard.

The Short Circuit Rating Of This Panelboard Chassis Is Equal To The Lowest Current Interrupting Rating Of Any Device Installed Except As Noted In The Series Rating Information Manual Attached.

ASSEMBLED IN U.S.A.

900P281H01 R2









**EAT•N**

SPD Series  
Surge Protective Device

160kA

Protection Status

A

B

C

Neu/  
Gnd

Alarm  
Silence

Protected



Replace



**RoHS**  
compliant

NOTI



11:23

5G%

◀ Search

**310.15 Ampacities for Conduc...**

- a. The cables do not have an overall outer jacket.
- b. The number of current carrying conductors exceeds 20.
- c. The cables are stacked or bundled longer than 600 mm (24 in) without spacing being maintained.

**Table 310.15(B)(3)(a) Adjustment Factors for More Than Three Current-Carrying Conductors**

Number of Conductors <sup>1</sup>	Percent of Values in Table 310.15(B)(16) through Table 310.15(B)(19) as Adjusted for Ambient Temperature if Necessary
4–6	80
7–9	70
10–20	50
21–30	45
31–40	40
41 and above	35

<sup>1</sup>Number of conductors is the total number of conductors in the raceway or cable, including spare conductors. The count shall be adjusted in accordance with 310.15(B)(5) and (6). The count shall not include conductors that are connected to electrical components but that cannot be simultaneously energized.

(b) *Raceway Spacing*. Spacing between raceways shall be maintained.

(c) *Raceways and Cables Exposed to Sunlight on Rooftops*. Where raceways or cables are exposed to direct sunlight on or above rooftops, the adjustments shown in [Table 310.15\(B\)\(3\)\(c\)](#) shall be added to the outdoor temperature to determine the applicable ambient temperature for application of the correction factors in [Table 310.15\(B\)\(2\)\(a\)](#) or [Table 310.15\(B\)\(2\)\(b\)](#).

*Exception:* Type XHHW-2 insulated conductors shall not be subject to this ampacity adjustment.

Informational Note: One source for the ambient temperatures in various locations is the ASHRAE *Handbook — Fundamentals*.

Home



&lt; Section

Section &gt;











E = 1200A  
F = 1400A  
G = 1500A  
H = 1600A =  $I_n$

201230



TEST / ALARM



$t_r$  (s)  
LONG

STATUS

Eng



$I_{sd}$  ( $\times I_r$ )  
SHORT



$t_{sd}$  (ms)  
SHORT

NP 6635C07 H24



330 N. 3<sup>rd</sup> Street, Bldg 200  
Sanger, TX 76266

Authorized Fire Pump Representatives Specializing in:

Sales - Testing - Services  
Motor Control Troubleshooting and Repair

[www.southwest-pumps.com](http://www.southwest-pumps.com)  
940-453-1231

**E.T.N**

UNIT: 16F456SE

UNIT CODE

SERVICE VOLTAGE 208

3 \* 3 = 60 Hz

WELL RATING 30HP

CONTROL VOLTAGE

CONTROL VOLTAGE SOURCE

S.S. 16F456SE

MADE AT: LIMA, PERU, CANADA





CHECKED ROTOR TRIP		SYSTEM INFORMATION		CUSTOMER INFORMATION	
FLA: 88	A	CAT NO: FT20-30-A-L1		PROJECT: FANNIN COUNTY	
ILD AT: 264	A	208V 30 HP 3 PH 60 HZ			
RIP AT: 528	A	CONTROL VOLTAGE: 120 V		CUSTOMER: Patterson Pump	
ID: 150/O.1		IC 25 KA SYM AT 208 V MAX		CUSTOMER #: _____	
		ENCLOSURE TYPE: 2 PRESSURE: 50Q PSI			
ROUTING 1 - JOB FILE 2 - PRODUCTION		LVCA CALGARY, AB			
NEW YORK CITY APPROVED MEA 18-02-E		DISTR. DATE AG 07/20/20		TITLE LIMITED SERVICE	FT20
		APPD. APPR. DATE AG 07/20/20		TITRE EPCT ELECTRIC FIRE PUMP CONTROLLER	
		APPD. APPR. DATE		TYPE ELECTRIC FIRE PUMP CONT.	WIRING DIAGRAM
PRODUCT CODE C.O. PRODUCT		REVISION 1	DWG SIZE / SCHELLE A	G.O. C.O. 16F4565	PAGE 1 OF 2
				DWG DESIGN 16F4565E	





























































































Model No. **C80 D6C**  
Modele

Serial No. **G200781947**  
Serie

Spec. **B**

**IMPORTANT!**

Model & Serial No. Required When Ordering Parts.

Modele & No. Serie Requis Pour Commander Des Pieces. **99-2433**

**CUMMINS POWER GENERATION**

1400 73RD AVE. N.E.

MINNEAPOLIS, MN 55432 U.S.A.

MADE IN U.S.A.

FREQUENCY		60 HZ			
SERVICE RATING		STANDBY		PRIME	
PHASE		1PH	3PH	1PH	3PH
RATED KW		0.0	80.0	0.0	0.0
POWER FACTOR		0.0	0.8	0.0	0.0
RATED KVA		0.0	100.0	0.0	0.0
12 CAPABILITY CONNECTION		8pct WYE			
BATTERY	VOLTS	AMPS		AMPS	
12 VDC	120/ 208	277.6			

ROTATING  
SPEED  
1800RPM

NOMINAL  
RATED

INSUL:  
CLASS H  
AMB 40C

FUEL:  
Diesel

MAX FLOW  
34 L/hr (8.9 gal/hr)

WIRING DIAGRAM

A054B421

A057P963



For Electrical Equipment Only  
Pour Material Electrique Seulement



**EATON**



LISTED

UL 100-1000-1000-1000

**EATON**

7720-30 6.11

TYPE 30

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000





























**E.T.N**

DWG: 16F4565E

UNIT LOC:           

SERVICE VOLTAGE 208V

3  $\phi$  3 W 60 HZ

MAX. RATING: 30HP

CONTROL VOLTAGE:            V

CONTROL VOLTAGE SOURCE:           

S.O.: 16F4565E

MADE AT: LVCA, AIRDRIE, CANADA

WIRED BY: EC DATE 07/23/20


TESTED BY:            DATE Jul 23/20

**ATTENTION**

The opening of the branch circuit protective device may be an indication that a fault has been interrupted. To reduce the risk of fire or electric shock current carrying parts and other components of the controller should be examined and replaced if damaged. If burnout of the current element of an overload occurs, the complete relay must be replaced.

Suitable for use on a circuit capable of delivering not more than            kA RMS symmetrical            Volts maximum when protected by            class fuses or a circuit breaker having an interrupting rating not less than 25 kA RMS sym 208 V max

5710A07H06 Rev 012



**NOTES:**  
1. POWER/PH ALARM RELAY NORMAL CON  
2. ALL RELAYS IN NO POWER

**LEGEND:**  
CB - CIRCUIT BREAKER  
CT - CURRENT TRANSFORMER  
N - RUN CIRCUIT  
MSH - MANUAL STOP

**OPTIONS**

1/FLOOR MOUNTING FEET









FM  
APPROVED

*The Pump People*  
**Patterson**  
A GORMAN-RUPP CO., TOCOGA, GEORGIA, USA  
CONTINUOUS FIVE PUMP IN-LINE



UL  
LISTED  
460









## For Units Supplied with Cause of Trip

To Enable Cause of Trip

Connect C1 to C9 on the CVD terminal block located on the left side of the breaker.

Label may be removed after installation.

70C1881H01

**EATON**

Industrial Circuit Breaker  
Frame

**RGH 65k**

**1600 AMPS      690VAC      3 POLE**  
**CAT RGH316038E**  
**STYLE # 1485D94Q21**  
**EQUIPPED WITH**  
**RQ310 + TRIP UNIT**  
**RT316038**

Interrupting Capacity - RMS Symmetrical Ampere  $\sim$  50/60 Hz


IEC 60947-2

Ik	Icu kA	Ics kA
240 $\sim$	125	100
415 $\sim$	70	50
690 $\sim$	25	13

Volt	kA
240 $\sim$	125
480 $\sim$	65
600 $\sim$	50



Uimp 8 kV Category A



Terminal Cat. No.	Wire Size AWG/SCW (mm <sup>2</sup> )	Conductor Material	Torque lb-in (Nm)
TA1600RD(M)	4 500 - 1000 (300 - 500)	CU/AL	650 (67)
T1600RD(M)	4 1 - 600 (50 - 300)	CU ONLY	375 (42)
TA2500RD(M)	3 470 - 500 (120 - 240)	CU/AL	500 (56)

### Accessories Installed

Shunt Trip	Auxiliary Switch	Under V. Release	Alarm/ Lockout
---------------	---------------------	---------------------	-------------------

Made in U.S.A.























































## PowerCommand


\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

- ☐ Genset Supplying Load
- ☐ Charger AC Failure
- ☐ Low Coolant Level
- ☐ Low Fuel Level
- ☐ Check Genset
- ☐ Not In Auto
- ☐ Genset Running
- ☐ High Battery Voltage
- ☐ Low Battery Voltage
- ☐ Weak Battery
- ☐ Fail To Start
- ☐ Low Coolant Temp
- ☐ Pre-High Engine Temp
- ☐ High Engine Temp
- ☐ Pre-Low Oil Pressure
- ☐ Low Oil Pressure
- ☐ Overspeed

Silence/  
Lamp Test

Network





# EATON®

## Pow-R-Line

### PRL-C Switchboard

Volts	208Y/120V	~	G. O. No.	SDA1136067
Phase	3	Wire 4	Item No.	003
Frequency	60 Hz		Section No.	1 Of 2
Mfd. At	GPS		Date	11/6/2020
Current Ratings - Amperes				
Supply	1600		Neut.	1600
Section	1600		Neut.	1600
Enclosure Type	3R			

SUITABLE ONLY FOR USE AS SERVICE EQUIPMENT.  
MAXIMUM OF SIX (6) DISCONNECTS

The Short-Circuit Rating is equal to the lowest:

- 1) short-circuit current rating of any switchboard section connected in series, and
- 2) short-circuit current rating of any installed panelboard that has a short-circuit current rating marked on it, and
- 3) The following:
  - 3a) interrupting rating of any installed circuit breaker or fused switch (excluding those located in a control circuit), or
  - 3b) interrupting rating of any combination of series-connected circuit breaker or fused switches as described within the attached Series Ratings Information Manual (Information Manual (IM) 1C16944H01), but is limited to a maximum of 65kA rms symmetrical amperes at 208 volts maximum.

\*900P025H01 R15

Assembled in USA













123.jpg.jpeg





22:53



merge-6844-2023-07-0...


Done

MCB Rating:

C	Poles	Trip	Circuit Description	CKT
				2
	3	225 A	PANEL "MB"	4
3... 2409...				6
				8
	3	600 A	PANEL "MA"	10
... 6179...				12
				14
	3	50 A	ELEVATOR	16
3... 5400...				18
				20
				22
				24
				26
				28
				30
				32
				34
				36
				38
				40
				42
5707 VA				
973 A				

Estimated Demand	Panel Totals	
23042 VA		
1080 VA	Total Conn. Load:	327526 VA
276044 VA	Total Est. Demand:	318846 VA
18680 VA	Total Conn. Current:	909 A
	Total Est. Demand Current:	885 A



<b>OPTIONS</b> 1/FLOOR MOUNTING FEET		<b>CIRCUIT BREAKER</b> TRIP AMP: 1050 _____ A TRIP SETTING: E _____		<b>LOCKED ROTOR TRIP</b> MOTOR FLA: 88 _____ A MUST HOLD AT: 264 _____ A MUST TRIP AT: 528 _____ A CT RATIO: 150/0.1 _____		<b>EAT•N</b> 	
<div style="display: flex; justify-content: space-between;"> <div style="width: 20%;"> <b>REVISION</b>  <div style="border: 1px solid black; padding: 2px;">1</div>         #PFA RELEASE          03/28/78          JLE/E       </div> <div style="width: 60%;"> <b>ROUTING</b>          1 - JOB FILE          2 - PRODUCTION            NEW YORK CITY          APPROVED          MEA 18-02-E       </div> <div style="width: 20%; font-size: small;">         EATON CORPORATION - 1          NOTICE TO THE USER: THIS DOCUMENT IS          THE PROPERTY OF EATON CORPORATION. IT IS          LOANED TO YOU BY EATON CORPORATION AND IS          NOT TO BE REPRODUCED OR TRANSMITTED IN          ANY FORM OR BY ANY MEANS, ELECTRONIC OR          MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING,          OR BY ANY INFORMATION STORAGE AND RETRIEVAL          SYSTEM, WITHOUT THE WRITTEN PERMISSION OF          EATON CORPORATION.       </div> </div>						<b>PRODUCT CODE</b> CODE PRODUCT	







































MAIN

SERVICE  
DISCONNECT



**For Units Supplied with Cause of Trip**  
To Enable Cause of Trip  
Current CI to CR on the C (Optional) block  
located on the left side of the breaker  
Labels may be removed after installation.

E.T-N

RGH 65kV

1000 AMP  
241 400V/200V  
SETL # 1000 200V  
MAGNETIC  
R0117 & TRIP UNIT  
R0117-000

Maximum Capacity: 1000 Amps at 200V AC  
at 60 Hz

CE

1000 200V

1000 200V

1000 200V

1000 200V






















**— WARNING —**

TO PREVENT DAMAGE TO GROUND FAULT CONTROL CIRCUITS, METERING CIRCUITS, OR OTHER CONTROL CIRCUITS, WHEN MEGGERING SWITCHBOARD, ISOLATE CIRCUITS FROM SWITCHBOARD SYSTEM BEFORE BEGINNING THE MEGGER OPERATION. BE SURE TO RECONNECT THOSE CIRCUITS AFTER MEGGER TESTS ARE COMPLETED.

NOTE: SOME GROUND FAULT CIRCUITS MAY NOT BE FUSED, THEREFORE ISOLATION





